

**WEST CENTRAL RAILWAY  
OFFICE OF DY. CMM (CRWS) BHOPAL  
TENDER SCHEDULE**

<b>WB-07/Normal</b>	<b>Tender</b> <b>18.07.2012</b>	<b>Date:</b>	<b>Tender</b> <b>30.07.2012</b>	<b>Due</b>	<b>On:</b>
<b>TENDER BOX TITLE &amp; COLOUR : NORMAL</b>			<b>Closing at- 15:00 Hrs.</b>		

M/s,

Tender No	Description	Quantity	Unit	Delivery Terms
68.12.5277	Pneumatic Pistol Grip Screw Driver Machine (Finder type) Trigger start, As per following specification No.02 specification attached.	12	Nos	30 days or At the earliest
68.12.5453	3Phase Vertical Submersible Pump Energy Efficient having 200LPM at 119Mtrs Head 10H.P. 14Stage 5 star rated pump Set. Make- Shakti/waterman/S.B. As per Specification Annexure 'A' Attached . Kirloskar/Atlanta/ Calama.	06	Set	30 days or At the earliest
68.12.5297	33KV Current Transformer type:out door polycrate (Dray type) Resin, No. of phase:single As per Specification Annexure 'E' attached make- CGL/KAPPA/Automatic Electric.	03	Nos	30 days or At the earliest

Terms:

- 1 INSPECTION BY CONSIGNEE
- 2 **Firms are advised to drop their quotations in the Tender Box labeled as NORMAL PURCHASE at Dy. CMM (CRWS) BHOPAL's office.**
- 3 Bill paying officer is Dy.FA&CAO-W/CRWS/BPL.
- 4 No Excise Duty on freight element will be payable. Vendors must indicate freight element separately otherwise it will be assumed that vendors are absorbing the freight themselves.
- 5 In cases of delays in contractual delivery, full LD will be levied as per conditions of contract and being a contractual provision no request for LD will be considered, notwithstanding any past instances of such waiver or less token LD.
- 6 Firm should quote taxes and excise duly clearly, failing which it will be presumed that same are included in rates and will be paid by firm.
- 7 The tenderers must quote Ex-works rate and FOR destination rate separately transportation by Rail/Road to each consignee, failing which their offer may be passed over.
- 8 In case rates quoted by firm are different in words and figures, the lower of the two shall be taken for all purpose during tender finalization, simultaneously keeping the right to pass over the tender.
- 9 Railway reserves the right to place the orders for part quantity on one or more sources and also to take delivery in installments.
- 10 IRS conditions of contract with latest amendment will be applicable.
- 11 Offer should be valid for a minimum period of 90 days.
- 12 Conditions of Advertised Tender as posted on [westcentralrailway.com](http://westcentralrailway.com) shall also be applicable
- 13 **Firm should have valid authorization certificate from OEM to quote in tender without which offer may be passed over.**
- 14 **Firm should submit the D.D. 10% of Total PO Value, as Security Deposit, at the time of P.O., same will be return after completion of work.**

**Dy.CMM/CRWS/BPL**

Fax No. 0755-2743643, 2747414, Email ID: [dycmm.pps@gmail.com](mailto:dycmm.pps@gmail.com)

Specification /AnnexureNo.2 Oof Tender No.68.12.5277 due 26.07.12

Detailed specification for Pneumatic Pistol Grip Screw Driver Machine.

Requisition: No.96141235 dt.18.06.2012.

Type of Pneumatic Screw Driver:-Pneumatic Pistol Grip Screw Driver Machine

Finder type Trigger Start.

Free speed :- 600RPM-to-800RPM

Torque Range:- 1.7Nm-14.00Nm

Overall length:- 228mm -249 mm(Approx)

Weight:- 1.00KG – 1.36 KG.

Body Diameter:- 44 mm approx.

Average air consumption:- 5.6cfm

Air inlet threads ¼”BSP Thread

Air Hose size to connect the M/Cs:8.00 mm-9.5mm

Make- IR. Or CP. Or IEC

Pneumatic Pistol Grip Screw Driver Machine along with finder suitable for Bit Hexagonal driver 6mm Bit part No. 1526 vessels or IR or CP.and finder part.No. 753140(S).

Guarantee :- Pneumatic Screw Driver Machine Should be guaranteed for one year from the date of receipt of the same. The firm should be OEM or its authorization certificate should be enclosed along with supply.

DyCMM/CRWS/BPL

Annexure-E

Specification of Tender No. 68.12.5297 due on 26.07.12

Specification of 33 KV Current Transformer.

a	Type of current transformer ,type of apply and earthing condition.	Out door ,polycrete (Resin)-dry type.
b	Highest system voltage ,type of supply and earthing condition	33KV,Single Phase,effectively earthed.
c	Rated insulation level.	36KV/70KV/170KVp
d	Rated Short time thermal current (and its duration if different from 1 second).	25KA for 1 Second.
e	Frequency (Other than 50Hz)	50Hz.
f	Rated transformer ratio:	100-50/5.5,5Amp.
g	Rated out put and corresponding accuracy class for measuring or protective current transformer.	No.of core-03. 1).Core NO.1,Class –PS.50v., lexc-100ma@VK/4.
h	Ratedtime point voltage and limitation of exixting current for class PS current transformers.	ii) CoreNo.2,class 0.5,15VA Measuring. iii) Core No.3,Class 5P10,Protection.
i)	Service Condition	CT is used out door and for normal weather conditions.
J)	Special features such as limiting dimensions	Nil

Dy.CMM/CRWS/BPL