

CORRIGENDUM

Kindly refer this office E-Procurement Bulletin tender no. **40.12.1543** due on **18.12.2012**, published in advertised **Bulletin no.51/12**. The amendments made are as under:

S.No.	Original Description	Modified Description
1.	Metal Clad Switch Fuse Unit but triple pole having rates voltage of 415 Volts.	Three Phase triple pole with neutral link, weather proof metal clad air break switch fuse Unit, conforming to IS13947(Part 1 & 3)/1993(Reaffirmed-2004)with positive make and brake arrangement, suitable for three phase 415 Volts,50Hz AC supply. It shall be fitted with interlock able arrangements and with following ratings and utilization categories:-Rated Current in AMPS:63,utilization Category:AC-23A

Latest terms & condition and full information is available on website www.ireps.gov.in, www.wcr.indianrailways.gov.in

**For Controller of Stores
WCR/JBP**