



- NOTES:-
- * 1) DC-DC CONVERTER MODULE FOR BLOCK LINE UP & DN SHALL BE OF RATING 60-100V, 1A & 12-40V, 1A IN THE RATIO 1:1 AND IF THE SECTION IS PROVIDED WITH BPAC USING BLOCK PANEL THEN BLOCK LINE UP & DN NOT REQUIRED.
 - 2) APPROXIMATE CABLE DISTANCE BETWEEN IPS ROOM & ASM PANEL 35 METERS.
 - 3) APPROXIMATE CABLE DISTANCE BETWEEN IPS ROOM & BATTERY BANK 25MTRS.

DRAWN BY <i>[Signature]</i> S.E.(D)	CHECKED BY <i>[Signature]</i> ESTB-110	CHECKED BY <i>[Signature]</i> Dy. S. I. E. (P & U)	APPROVED BY DT: <i>[Signature]</i> C.S. I. E. / Proj.	WEST CENTRAL RAILWAY SIGNAL & TELECOMMUNICATIONS IPS FOR UP TO 6 LINES WITHOUT AFTC FOR RE / NON RE AREA DRG. NO. WCRN-HQPS/SEL/165/003
---	--	--	--	---

जि. एस. मीना
 J. S. MEENA
 Dy. Chief Materials Manager/G&C