

Technical clarification regarding description of material of Tender No. 40.14.8028

SN	Query raised	Remarks
1	Is the escalator required at entry, exit or platform in the station?	Yes. Escalators will be provided at entry and exit side of the station. It will also be provided at island platform for upward and downward movement of passenger.
2	What is the height of the foot over bridge (at passenger walking level from base)?	The minimum height of FOB from rail level is 6.250 mtrs. The platform height varies from 760 mm to 480 mm depends upon station to station. Hence, approximate height of FOB from platform surface is about 5.77 mtrs.
3	Horizontal spaces available for escalator's installation	Adequate horizontal space is available for housing of escalator. Normally, 17 to 18 mtrs. space is required for housing of escalator.
4	Location of step chain roller	It is a design aspect of the escalator and location of step chain roller can be provided as per design of escalator.
5	Handrail guidance at newels	Handrail guidance shall be made available as per RDSO's specification.
6	Is sprinkler system required?	Not required. However, it will be as per RDSO's specification.
7	Will the escalator be installed at an underground station?	No. Escalators will be provided between platform surface to foot over bridge for upward and downward movement of passengers.

However, the representative shall visit the work site before quoting his offer.

Amend
 CETE/Plg
 29.12.13