

Annexure of PAC against PL No 25718952

COS File no. 20.15.3561

2/

SR NO	CODE NO.	DESCRIPTION	QTY/ VCB	
1	2	3	5	
A.	5110610	PART I - AOH REPLACEMENT KIT CONSISTING OF :	1 Kit	
1	5380750	SEALING STRIP FOR CRADLE AND COVER.	3	MTRS.
2	5150070	'O' RING FOR AIR VALVE ASSLY	1	NO.
3	5150080	'O' RING FOR AIR VALVE ASSLY	3	NOS.
4	5150020	PTFE VALVE DISC FOR AIR VALVE ASSLY	2	NOS.
5	5260700	O RING FOR MAGNET VALVE & MANIFOLD	5	NOS.
6	5260800	O RING FOR MAGNET VALVE ASSLY	2	NOS.
7	5260600	VALVE (FLUTED)FOR MAGNET VALVE	2	NOS.
8	5142040	O RING FOR RESERVOIR ASSLY	1	NO.
9	86700241	MOLYGRAPH 44 GREASE	1	TUBE
10	3410-55	DIAPHRAGM ASSLY FOR PRESSURE REGULATOR		
11	5110600	REPLACEMENT KIT FOR AIR FILTER CONSISTING OF :	1	SET.
	251524	O RING	-	
	364301	GASKET	-	
	364302	GASKET	-	
	364589	STUD	-	
		PART II - ADDITIONAL LOOSE ITEMS		
B	5110422	REPAIR KIT FOR PRESSURE REGULATOR IOH CONSISTING OF :	1	KIT.
	341056	DIAPHRAGM ASSEMBLY	-	
	61501	SLIPRING	-	
	295901	VALVE	-	
	340284	VALVE SEAT	-	
	195606	GASKET SEAT	-	
	279901	VALVE SPRING	-	
C	5390100	MOLECULAR SIEVE FOR AIR DRYER IOH (4 Kg Pack)	4	KG.
D	5140020	'O' RING FOR RESERVOIR ASSLY POH	2	NOS.
		RATE PER SET EACH		

AE EE/10/21/15
WCR

अरुण कुमार
Arun Kumar
वरिष्ठ सामग्री प्रबंधक (विद्युत-I)
Senior Material Manager (Elec. -I)
प.म.रे., जबलपुर/W.C.R., JBP.

अरुण कुमार
Arun Kumar
वरिष्ठ सामग्री प्रबंधक (विद्युत-I)
Senior Material Manager (Elec. -I)
प.म.रे., जबलपुर/W.C.R., JBP.

Schneider Electric Infrastructure Limited
(the demerged Distribution undertaking of AREVA T&D India Limited)
Tel: 011 671142, Fax: 011 671143, Corporate Park, Sector 18, Gurgaon, Haryana
Tel: 022 3940 4000, Fax: 022 3073 8800 www.schneider-electric.com