

Specification of "RTU"

Detail of RTU of 64 digital input and 16 analog inputs as per item no. 11.1.13 of RDSO specification no. IRS: S-99/2006 (Amdt-3).

The digital and analog inputs are to be monitored from RTU:

Type of input	No. of Channel	Distance from Data logger
DIGITAL	64	Approx 6Km
ANALOG	16 as given below	-do-
230V AC	04	
110V AC	04	
60V DC	03	
24V DC	04	
110V DC	01	

(J.S.MEENA)
DY.CMM/G&C
For Controller of Stores

जे. एस. मीणा
J. S. MEENA

उप मुख्य सामग्री प्रबन्धक/जी.एण्ड सी.
Dy. Chief Materials Manager/G&C

पश्चिम मध्य रेल, जबलपुर
West Central Railway, Jabalpur