

Sr. No.	Revisions in WCR Specification WCR/JBP/Specification/GS/001(Rev.0)2016.
1	<p><u>Revision (1) 2017 in WCR Spec. No. WCR/JBP/Specification/GS/001(Rev.0)2016.</u></p> <p>Energy efficient LED based Luminaire for outdoor & Indoor application (General Service) in Test scheme , item 8.5, acceptance test following item is added:</p> <p>“One sample from the offered lot will be taken and got inspected in NABL approved lab for parameter as per specification No. WCR/JBP/Specification/GS/001(Rv.0)2016. The payment of testing will be borne by supplier. The report will be sent to consignee along with test certificate by RITES”.</p>
2	<p><u>Revision (2) 2017 in WCR Spec. No. WCR/JBP/Specification/(GS)/001(Rev.0)2016</u></p> <p>For Energy efficient LED based Luminaire for outdoor and indoor application (General Service) on Prototype Test, item 8.1 has been issued with the approval of competent authority (CEE/WCR) w.e.f 09.08.2017 is as under:-</p> <p>“Prototype test shall be conducted on the first unit developed by the firm as per the relevant Specification. After successful proto type test the proto type sample shall be got certified for meeting LM79 specification from UL/any NABL approved laboratories. The proto type tests undertaken at firm’s premises may be witnessed by authorized Railway/RITES representative as per inspection clause. And the firm will submit test certificate for other tests conducted by at government approved labs. Only after certified by Railways/ RITES for the above clearance for bulk manufacturing will be given by Railway”.</p>